

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
10/30/03	10/30/03	38251	EMWD	Brodiaea & Kitching Ave., Moreno Valley, Riverside County	SSO	19,250	An estimated 19,250 gallons of sewage overflowed from a manhole due to vandalism. A large piece of lumber was stuck sideways in the sewer line which caused the overflow. All 19,250 gallons of the spill were contained in the Perris storm drain, recovered, and returned to the operational sewer system. The lumber was removed, the sewer line was repaired and the affected area was cleaned up by EMWD's staff.
10/31/03	10/31/03	38244	Private Property Owner	Mac Arther Blvd., Newport Beach, Orange County	SSO	---	Unknown amount of sewage overflowed from a private force main due to a broken force main line. 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system while the remainder of the spill discharged into a local storm drain and flowed to Newport Back Bay. The broken line was repaired, the affected area was cleaned up and disinfected by a private contractor with assistance of Newport Beach City staff.
11/1/03	11/1/03	38247	City of Beaumont	1300 Beaumont Ave., Beaumont, Riverside County	SSO	9,250	An estimated 9,250 gallons of sewage overflowed from a manhole due to grease blockage. Due to extensive vegetation in the area, they were unable to contain the spill. All the spill entered into the local storm drain. The blockage was cleared, the affected area was cleaned up and disinfected by the City of Beaumont staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/12/03	11/12/03	38243	IRWD	11 Halstead Terrace, Irvine, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to tree root blockage. All 500 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was removed, the affected area was cleaned up and disinfected by the IRWD's staff.
11/12/03	11/12/03	38250	Private Property Owner	10201 Valley View, Cypress, Orange County	SSO	600	An estimated 600 gallons of sewage overflowed from a private manhole due to grease blockage. None of the spill was recovered and it discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by a private contractor with assistance of the City of Cypress staff.
11/16/03	11/16/03	38203	City of Stanton	7800 Katella Ave, Stanton, Orange County	SSO	2,000	An estimated 2,000 gallons of sewage overflowed from a manhole due to grease blockage. 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, and the affected area was cleaned up and disinfected by City of Stanton staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/16/03	11/16/03	38245	City of Garden Grove	12502 Grove View, Garden Grove, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to tree root blockage. All 500 gallons of the spill were contained, recovered, and returned to the operational sewer system. The tree roots was removed and the sewer line was cleared, and the affected area was cleaned up and disinfected by the City of Garden Grove staff.
11/17/03	11/17/03	38246	City of Anaheim	5665 E. La Palma Avenue, Anaheim, Orange County	SSO	2,700	An estimated 2,700 gallons of sewage overflowed from a manhole due to unknown blockage. 700 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into the local storm drain and flowed to the Santa Ana River. The blockage was removed, the affected area was cleaned up and disinfected by City of Anaheim staff.
11/18/03	11/18/03	38248	City of Beaumont	Nobel Creek Lift Station, Beaumont, Riverside County	SSO	4,500	An estimated 4,500 gallons of sewage overflowed from a lift station due to grease blockage. 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest discharged into the local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Beaumont.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/20/03	11/20/03	38167	City of Riverside	Howard Ave. between Prospect & Park Ave., Riverside, Riverside County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to grease blockage. 200 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest discharged into the local storm drain which flows to the Santa Ana River. The blockage was removed, the affected area was cleaned up and disinfected by the City of Riverside staff.
11/21/03	11/21/03	38163	City of Orange	Chandler Ranch Rd. @ Pinto Way, Orange, Orange County	SSO	800	An estimated 800 gallons of sewage overflowed from a manhole due to grease blockage. 300 gallons of the spill were contained, recovered, and returned to the operational sewer system. 500 gallons of the spill were not recovered and discharged into a local storm drain, which flowed to San Diego Creek. The blockage was removed, the contaminated area was cleaned up and disinfected by the City of Orange staff.
11/21/03	11/21/03	38249	City of Anaheim	6501 Nohl Ranch Road, Anaheim, Orange County	SSO	9,400	An estimated 9,400 gallons of sewage overflowed from a manhole due to construction debris blockage. 9,000 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The construction debris was removed from the manhole, the affected area was cleaned up and disinfected by the City of Anaheim staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/21/03	11/21/03	38164	City of Anaheim	Knoll Ranch & Walnut Cyn Rd. Anaheim, Orange County	SSO	1,500	An estimated 1,500 gallons of sewage overflowed from a broken sewer line due to construction in the area. 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. 500 gallons of the spill were not recovered and discharged into the local storm drain. The broken sewer line was repaired, the affected area was cleaned up and disinfected by the City of Anaheim staff.
11/23/03	11/23/03	38255	Private Property Owner	901 E. Heim Ave. Orange, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a private lateral due to grease blockage. None of the spill was recovered and it discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by a private contractor.
11/24/03	11/24/03	38168	Private Property Owner	5773 Clifford, Riverside, Riverside County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a private property owner's lateral due to grease blockage. All 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was removed, the affected area was cleaned up and disinfected by the private property owner with assistance of City of Riverside staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/24/03	11/24/03	38254	City of Riverside	Laramie and Carson Road, Riverside, Riverside County	SSO	966	An estimated 966 gallons of sewage overflowed from a manhole due to grease blockage. 483 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into the local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Riverside staff.
11/28/03	11/28/03	38252	Private Property Owner	1223 University Ave., Riverside, Riverside County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a private lateral due to grease blockage. 500 gallons of the spill were contained, recovered, and returned into the operational sewer system while the rest of the spill discharged to the local storm drain and flowed to the Santa Ana River. The blockage was removed, the affected area was cleaned up and disinfected by a private contractor with assistance of the City of Riverside staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
11/29/03	11/29/03	38264	OCSD	La Colima & Irvine Blvd., Orange, Orange County	SSO	1,850	An estimated 1,850 gallons of sewage overflowed from a manhole due to tree root blockage. 617 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain and flowed to San Diego Creek. The blockage was removed, the affected area was cleaned up and disinfected by OCSD's staff.
11/30/03	11/30/03	38253	City of Yorba Linda	Allonby Circle, Yorba Linda, Orange County	SSO	3,000	An estimated 3,000 gallons of sewage overflowed from a manhole due to tree root blockage. None of the spill was recovered and it discharged into a local storm drain. The tree roots were removed, the affected area was cleaned up and disinfected by the City of Yorba Linda staff.
12/2/03	12/1/03	38330	City of Anaheim	1758 W. Sumac Lane, Anaheim, Orange County	SSO	1,600	An estimated 1,600 gallons of sewage overflowed from a manhole due to tree root blockage. All 1,600 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared, the affected area was cleaned up and disinfected by the City of Anaheim staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
12/3/03	12/3/03	38263	City of Orange	545 N. Batavia, Orange, Orange County	SSO	450	An estimated 450 gallons of sewage overflowed from a manhole due to grease blockage. All 450 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was removed, the affected area was cleaned up and disinfected by the City of Orange staff.
12/9/03	12/9/03	38327	Private Property Owner	815 Indianapolis Ave, Huntington Beach, Orange County	SSO	1,500	An estimated 1,500 gallons of sewage overflowed from a manhole due to grease blockage. All 1,500 gallons of the spill discharged into a catch basin and were diverted to the lift station and recovered. The blockage was cleared, the affected area was cleaned up and disinfected by City of Huntington Beach staff.
12/10/03	12/10/03	38329	City of Anaheim	6103 Morningview Drive, Anaheim, Orange County	SSO	800	An estimated 800 gallons of sewage overflowed from a manhole due to tree root blockage. 500 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest discharged into a local storm drain. The blockage was cleared, the affected area was cleaned up and disinfected by the City of Anaheim staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
12/12/03	12/12/03	38364	Private contractor	Brooks St. Upland, San Bernardino County	SSO	2,000	An estimated 2,000 gallons of sewage leaked from a broken 15" vitrified clay pipe during construction. All 2,000 gallons of the spill were contained at the construction site, recovered, and returned to the operational sewer system. The broken pipe was repaired, the affected area was cleaned up and disinfected by the private contractor with assistance of Inland Empire Utilities staff.
12/15/03	12/11/03	38325	City of Corona	400 Block East 4th St., Corona, Riverside County	SSO	1,918	An estimated 1,918 gallons of sewage overflowed from a manhole due to tree root blockage. None of the spill was recovered and it discharged into a local storm drain and flowed to an unnamed Creek. The blockage was removed, the affected area was cleaned up and disinfected by the City of Corona staff.
12/15/03	12/15/03	32292	Private Property Owner	2045 South Haster St, Anaheim, Orange County	SSO	3,000	An estimated 3,000 gallons of sewage overflowed from a manhole due to grease blockage. Approximately 2,000 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest discharged into a nearby storm drain. The blockage was cleared and the affected area was cleaned up by the private property owner.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
12/15/03	12/15/03	38365	City of Rialto	1441 Riverside Ave., Rialto, Riverside County	SSO	1,500	An estimated 1,500 gallons of sewage overflowed from a manhole due to tree roots blockage. An unknown amount of the spill was contained, recovered and returned to the operational sewer system while the rest discharged into a field which has been designated as being a habitat for the Delhi Sands Flower-Loving Fly. The tree roots were removed, the affected area has been posted for warning of the sewage spill by the City of Rialto.
12/15/03	12/15/03	38326	Huntington Beach	4171 Andros, Huntington Beach, Orange County	SSO	943	An estimated 943 gallons of sewage overflowed from a manhole due to grease blockage. 470 gallons of the spill were contained, recovered, and returned into the operational sewer system while the rest discharged into a local storm drain and flowed to Huntington Harbor. The blockage was removed, the affected area was cleaned up and disinfected by the City of Huntington Beach staff.
12/15/03	12/15/03	38324	Private Property Owner	East Vineyard Ave, Rancho Cucamonga, San Bernardino County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to debris dumped in the manhole by vandals. All 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The debris was removed, the affected area was cleaned up and disinfected by the City of Rancho Cucamonga staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
12/22/03	12/21/03	38363	City of Beaumont	Rose & Indigo, Beaumont, Riverside County	SSO	1,300	An estimated 1,300 gallons of sewage overflowed from a manhole due to construction debris blockage in a new development unit. All 1,300 gallons of the spill were contained, recovered, and returned to the operational sewer system. The debris was removed, the affected area was cleaned up and disinfected by the City of Beaumont staff.
12/23/03	12/23/03	32290	City of Anaheim	414 Bush St, Anaheim, Orange County	SSO	1,800	An estimated 1,800 gallons of sewage overflowed from a manhole due to grease blockage. All 1,800 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up by City of Anaheim staff.

Summary Report of Hazardous Waste and Sewage Spill Incidents per Water Code Section 13271

I. Petroleum Products

Date Reported*	Date Discovered	Discharger	Location	Problem	Action
6/9/03	5/21/03	A&M TEXACO SERVICE STATION	235 W. VALENCIA MESA DR., FULLERTON	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	CASE CLOSED
6/10/03	6/4/03	ARCO #1250	403 D STREET, PERRIS	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	SITE WORKPLAN UNDERWAY
7/14/03	5/30/03	HERTZ RENT-A-CAR	221 KATELLA AVE., W., ANAHEIM	UNDERGROUND STORAGE TANK LEAK: CONTAMINATED SOIL	SITE WORKPLAN SUBMITTED
7/16/03	7/16/03	EXXONMOBIL #18-KB5	19002 BROOKHURST STREET, HUNTINGTON BEACH	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	SITE WORKPLAN SUBMITTED
9/10/03	3/25/03	TEXACO OIL	6189 DAY STREET, RIVERSIDE	UNDERGROUND STORAGE TANK LEAK: CONTAMINATED SOIL	LEAK BEING CONFIRMED
9/22/03	9/22/03	AL ROHRS AND SON, INC.	1436 W. SANTA ANA STREET, ANAHEIM	UNDERGROUND STORAGE TANK LEAK: DIESEL CONTAMINATED SOIL	SITE WORKPLAN UNDERWAY
10/7/03	7/29/03	UNIVERSITY OF CALIFORNIA IRVINE	897 PELTASON, IRVINE	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	LEAK BEING CONFIRMED
12/9/03	11/20/03	CROSSROADS FUEL	101 BIG BEAR BOULEVARD, WEST, BIG BEAR CITY	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	SITE WORKPLAN SUBMITTED
12/10/03	12/2/03	TOWN & COUNTRY CAR WASH	2747 CHAPMAN AVENUE, ORANGE	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	LEAK BEING CONFIRMED

*Report date is the date on the Unauthorized Release Report which is filled out by the local agency or the discharger. This report may not contain an accurate listing of all the new cases and their current status due to the ongoing reconciliation between the Geotracker/GEIMS, DOD, and Local Agency databases.